

CITY OF FORT COLLINS

ADDENDUM No. 2

Bid No. 5761

SPECIFICATIONS AND CONTRACT DOCUMENTS

Description of Bid: Cable, Underground, 15KV, 750KCM

OPENING DATE: 2:00 p.m. (our clock), February 7, 2002

To all prospective bidders under the specifications and contract documents described above, the following changes are hereby made.

Changes outlined in **Addendum 1** are hereby **rescinded**.

The diameter over insulation (DOI) in the description for the cable on Bid #5761 has been revised from 1.460+/-30 mils to 1.490+/-30 mils and the diameter over shield (DOS) has been revised from 1.500+/-50 mils to 1.590+/-50 mils. The complete description is shown below.

The conductor shield shall be Dow/Union Carbide HFDA-0802 not HFDA-0800 as required in paragraph 3.2.2.2 of City of Fort Collins specification 367-102.

CABLE, UNDERGROUND, 15kV, 750 KCM, 61 STRD, BLOCKED STRD COMPRESSED AL CONDUCTOR, MIN 20 MILS SEMI-CONDUCTING XLP CONDUCTOR SHIELD, 220 MILS NOMINAL TRXLPE INSULATION, 1.490" +/-30 MILS DOI, MIN 40 MILS SEMI-CONDUCTING BLACK XLP INSULATION SHIELD, 1.590" +/-50 MILS DOS, 12-#12 AWG UNTINNED COPPER CONCENTRIC NEUTRAL, PER SPEC. NO. 367-102 REV E, SERIAL 03 EXCEPT 220 MILS INSULATION THICKNESS, 12 #12 NEUTRAL, AND NO JACKET. SHIP ON LAGGED N/R REELS MEETING THE FOLLOWING REQUIREMENTS: MAX FLANGE DIA 70", MAX O/A WIDTH 37", MIN DRUM DIA 28", MIN RIM CLEAR 2", 1400 +/-25' REEL (SEE SUPPLEMENTAL INSTRUCTIONS FOR SHIPPING)

ATTENTION is also directed to the Exception of 220 mils insulation thickness, 12#12 neutral, and no jacket in the description.

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED BY A WRITTEN STATEMENT ENCLOSED WITH THE BID/QUOTE STATING THAT THIS ADDENDUM HAS BEEN RECEIVED.