



CITY OF FORT COLLINS

**ADDENDUM No. 3
BID #5759
DOWNTOWN ENHANCEMENT PROJECT**

SPECIFICATIONS AND CONTRACT DOCUMENTS

Description of Bid #5759 Downtown Enhancement Project

OPENING DATE: February 12, 2003, 3:00 p.m. (Our Clock)

To all prospective bidders under the specifications and contract documents described above, the following changes are hereby made.

1. Paragraph 2 of Revision of Section 609, Curb and Gutter, shall be deleted and replaced with the following:

" Subsection 609.02 is revised to include the following: Curb and Gutter shall conform to Class "B" concrete as specified in 601.02 and 601.03. Class "B" concrete shall have a minimum 48-hour field compressive strength of 3000 psi, and a 28-day field compressive strength of 3500 psi."

2. For clarification, all items in Section 608 may be Class "B" with the exception that the minimum 28-day compressive strength shall be 3500 psi.

3. For clarification, the cost of furnishing and placing dowels shall be included in the cost of the concrete pavement.

If you have any questions please contact John Stephen, CPPB, Senior Buyers, at 970-221-6777.

**RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED BY A WRITTEN STATEMENT
ENCLOSED WITH THE BID/QUOTE STATING THAT THIS ADDENDUM HAS BEEN RECEIVED.**