



Administrative Services

Purchasing Division

CITY OF FORT COLLINS

ADDENDUM No. 1

BID #5792

LINCOLN CENTER HVAC & ROOF REPLACEMENT

SPECIFICATIONS AND CONTRACT DOCUMENTS

Description of Bid #5792 Lincoln Center Multi-Unit HVAC & Roof Replacement

OPENING DATE: June 24, 2003, 3:00p.m. (Our Clock)

To all prospective bidders under the specifications and contract documents described above, the following changes are hereby made.

A. General:

The crane company that was consulted with during design was Ridge Crane, Ft. Collins, CO

The roof on the east roof where three temporary units will be placed is under warranty by Douglass Roofing. Contractor shall contract with Douglass Roofing for repair of this roof after the removal of the temporary HVAC platforms.

Existing Electrical Wiring in Plenum Area

The existing electrical wiring in the plenum area may be removed if not in use after the demolition of the existing HVAC units or if existing and to remain in use shall be put in rated conduit.

Delete duct CO2 sensors in RTU's 2,3,4,5.

It is assumed the fire alarm control panel can handle the additional duct detectors. Fire alarm wiring shall be in conduit.

Electrical notes call to match the existing at panel HBA, breaker size shall be as required by the system design.

Sheet E1,

Electrical Notes, Add the following to Note 4: Locate existing duct detector wiring in ACU-6, 9, and 10 and relocate and add to existing wiring as required to serve the new duct detectors. Coordinate this work with the City Project Manager and the City Fire Alarm Technician. The City Fire Alarm Technician will be responsible to address the new detectors.

If you have any questions please contact John Stephen, CPPB, Senior Buyer, at 970-221-6777.

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED BY A WRITTEN STATEMENT ENCLOSED WITH THE BID/QUOTE STATING THAT THIS ADDENDUM HAS BEEN RECEIVED.

June 17,2003

CITY OF FORT COLLINS
PLANHOLDERS LIST FOR
BID #5792
LINCOLN CENTER MULTI-UNIT HVAC & ROOF REPLACEMENT

A&M ELECTRIC
128 COMMERCE DR
FT. COLLINS, CO 80524
PH 970-416-9734
FAX 970-416-9735

FRONT RANGE ROOFING
2419 6TH AVE
GREELEY, CO 80631
PH 970-353-2322
FAX 970-352-5757

SUN CONSTRUCTION & DESIGN
1232 BOSTON AVE
LONGMONT, CO 80501
PH 303-444-4780
FAX 303-444-6774

GROWLING BEAR COMPANY
2330 4TH AVE.
GREELEY, CO 80631
PH 970-353-6964
FAX 970-353-6974

MARK YOUNG CONSTRUCTION
155 N COLLEGE AVE STE 220
FT. COLLINS, CO 80524
PH 970-484-1648
FAX 970-224-0392

POUDRE VALLEY AIR
2416 DONELLA CT. #A
FT. COLLINS, CO 80524-1432
PH 970-493-2050
FAX 970-493-2073

SINNETT BUILDERS
PO BOX 1969
FT. COLLINS, CO 80522
PH 970-493-1770
FAX 970-482-4537

DOUGLAS ROOFING
110 14TH AVE.
GREELEY, CO 80631
PH 970-352-2040
FAX 970-352-3376

SIMPSON COMPANY
P O BOX 270653
FT. COLLINS, CO 80527
PH 970-282-0022
FAX 970-282-0020

UNITED MATERIALS INC.
P O BOX 40568
DENVER, CO 80204
PH 303-623-4166
FAX 303-892-1615