

75031093

FIRM NAME _____

CITY OF FORT COLLINS
BID PROPOSAL
BID # 5930
BID OPENING: 3:00 p.m. – August

WE HEREBY ENTER OUR QUOTE FOR THE CITY OF FORT COLLINS' REQUIREMENTS FOR LP CABLE, UNDERGROUND, 15KV, JACKETED PER THE BID INVITATION AND ANY REFERENCED SPECIFICATIONS.

QUANTITY

DESCRIPTION

300,000 Ft.

CABLE, UNDERGROUND, 15kv, JACKETED #1/0 AWG, 19 STRD., AL, .012" MINIMUM THICKNESS SEMI-CONDUCTING XLP CONDUCTOR SHIELD, .220" NOMINAL THICKNESS UNFILLED TRXLPE INSULATION, .860" +/-30 MILS DOI, .030" MINIMUM THICKNESS SEMI-CONDUCTING XLP INSULATION SHIELD, .940" +/-50 MILS DOS, 16-#14 BARE, UNTINNED COPPER CONCENTRIC NEUTRAL, .040" MINIMUM THICKNESS BLACK LLDPE ENCAP JACKET, PER SPEC. NO. 367-102, REV. J,

SHIP ON 5032 N/R 2500' REELS +/-200' (SUPPLEMENTAL INSTRUCTIONS FOR SHIPPING CONTAINED IN SPEC)

Certified test report on each production run, including actual production test values, are required.

\$ _____/Mft. _____ Total,
Including applicable tariffs and duties, if manufactured outside the

U.S.A

Mfr. _____ Mfr.# _____

Bid shall be a firm bid without escalation.

DESIRED SHIPPING SCHEDULE

- 75,000 FT - February**
- 75,000 FT - March**
- 75,000 FT - April**
- 75,000 FT - May**

09/10/19