

DATE: 8/6/82

DEPARTMENT ENGINEERING

Dept. Comments subdivision / p.u.d. FINAL

Item #53-82

C. C. & Company
P.U.D

Comments

DO WE NEED TO CHECK THE VALIDITY OF THEIR LIQUOR LICENSE?

WHAT ARE MOTORBIKES DOING PARKED IN THE DRIVE ENTRANCE? Suggest closing curb cut

CAN FIRE GET TO ALL PTS. of BLDG. ? ok

Walk may need to be brought up to City Standards

Sign encroaches on handicap ramp.
Handicap ramp at corner of City Park Elizabeth

Motorcycle parking does not conform to parking standards

No parking in ROW

Handicap is in poor location

Show street ROW

No new bldgs so need letter stating that
& that storm drainage won't change