

DATE: 6 May 87

DEPARTMENT: Eng

ITEM: 53-85E CENTRE FOR ADVANCED TECHNOLOGY, 3rd Filing - Pre & Final

No Problems

Problems or Concerns (see below)

- Ditch Company approval is needed for improvements proposed within their easement. Require signed approval on the Utility Plans.
- Soil report is not for this site. — provide correct report.
- Walk connections to the street are required at logical locations likely to be used
- I will set up a utility coordination meeting during the week of May 26th to discuss Mountain Bell's concerns of front easement widths

Date 5/19/87

Signature M. Hazy

DATE: 6 May 87

DEPARTMENT: MOBELL

ITEM: 53-85E CENTRE FOR ADVANCED TECHNOLOGY, 3rd Filing - Pre & Final

No Problems

Problems or Concerns (see below)

REQUEST WIDER FRONT EASEMENT.
I WOULD SUGGEST A UTILITY
COORDINATION MEETING WITH DEVELOPER,
TO DISCUSS POSSIBLE ROUTES OF
UTILITY TRUNK LINES, AND THE
EFFECT THESE ROUTES COULD HAVE
ON PROPOSED WIDTH OF FRONT
LOT UTILITY EASEMENTS.

5-11-87

S. Thompson

Date

Signature