

Dept. Comments subdivision / p.u.d. FINAL

Item # 76-79 C
CEDAR VILLAGE 6th FINAL

Comments

It is requested that all ^{utility} easements adjacent to street right of way lines on both sides of all streets be platted as 8' wide rather than 6' wide.

Gary Huett
PSC
12/2/79

RECEIVED
DEC 11 1979
Engineering Department

Dept. Comments subdivision / p.u.d. FINAL

Item # 76-79 C
CEDAR VILLAGE 6th FINAL

Comments

- ① TRACTS A, B & C MUST BE DEDICATED TO CITY.
- ② PLAT SHOULD STATE - PLAT OF CV 6th