



City of Fort Collins
Current Planning

PROJECT COMMENT SHEET

DATE: March 6, 2000

DEPT: ENGINEERING

PROJECT: #54-98A Poudre High School Wireless

Telecommunications, US West – Type I (LUC)

PLANNER: Ted Shepard

ENGINEER: Tim Blandford

All comments must be received by: March 22, 2000

No Problems

Problems or Concerns (see below or attached)

Comments:

- Access easement to the facility.
- Need to secure all necessary easements for the construction of the facilities from the Poudre School District.
- Show the access roadway to the facility as per Section 3.8.13(C)(11) of the Land Use Code (LUC).
- List the colors and materials being proposed for the different structures.
- Fencing material needs to be wood, masonry, or stucco as per Section 3.8.13(C)(5) of the LUC.
- The proposed fence cannot exceed 6 feet in height as per Section 3.8.13(C)(5) of the LUC.
- Provide landscaping as per Section 3.8.13(C)(4) of the LUC.

Date: March 7, 2000

Signature: 

PLEASE SEND COPIES OF MARKED REVISIONS

Plat Site Utility Landscape Drainage Report NO COMMENTS-SUBMIT MYLARS