

# Colorado Precast Concrete, Inc.

1820 S.E. 14th Street • Loveland, Colorado 80537-8805 • (303) 669-0535 • FAX (303) 669-0674

17 April 1995


Mr. Gary Gerrard  
Gerrard Excavating  
1739 S. County Road 13C  
Loveland, CO 80537

RE: Vacuum Testing

Dear Gary:

Colorado Precast Concrete, Inc. tested eight manholes for Gerrard Excavating on February 27, 1995. The manholes were located at the Silver Oaks Project in Fort Collins. They were tested at the top of manhole cone for one minute at 10 hg. inchs. The manholes that were tested (see list below) passed the vacuum test within the required criteria.

Respectfully Submitted,



Cindy S. Buckardt, CCA  
Colorado Precast Concrete, Inc.

cc: Steve Biegler - Engineering Department  
City of Fort Collins

