

Colorado Precast Concrete, Inc.

1820 S.E. 14th Street • Loveland, Colorado 80537-8805 • (303) 669-0535 • FAX (303) 669-0674

482-8658

REC.D '93OCT15PM12:08

October 13, 1993


Mr. Gary Gerrard
Gerrard Excavating
6124 Mangrove Court
Loveland, CO 80538

RE: Vacuum Testing

Dear Gary:

Colorado Precast Concrete, Inc. tested manholes for Gerrard Excavating on September 21st. The manholes were located at Colorado State University Housing Facility. They were tested at ground level (finish grade) for one minute at 10 hg. in. All of the manholes passed the vacuum test within the required criteria.

Respectfully Submitted,




Cindy S. Buckardt, CCA
Colorado Precast Concrete, Inc.

cc: Todd Jergens - Engineering Department
City of Fort Collins
P.O. Box 580
Ft. Collins, CO 80522-0580



Colorado Precast Concrete, Inc.

1820 S.E. 14th Street
 Loveland, Colorado 80537
 Ph. (303) 669-0535



Date Sept 21 1991

Gerrard Ex

C.S.U. Housing

Sold by <u>CB</u>	Cash	Charge <input checked="" type="checkbox"/>	Mdse. Ret.	Job Plant	Mileage Mileage	By <u>BH</u>	Delivered <u>#12</u>	Unit
----------------------	------	---	------------	--------------	--------------------	-----------------	-------------------------	------

Quant.	Description	Price	Amount
4	MH Vacuum Tested		

#	Start	Fin.	Holes	Time
			lbs. lost	
10 4g	7.7	7.10	3-6"	1:20
10 4g	7.11	2-10"	5-8"	1:00
10 4g	9.10	1-10"	6"	1:00
10 4g	9.2	1-10"	2"	1:00

Send me 1-10-12 Toed

NO 32459

Sub-Total
St. Sales Tax
TOTAL

Received by _____

2% interest per month (annual rate: 24%) charged on all accounts 30 days past due.