



PIPE OUTLET WITH GRAVEL FILTER

GENERAL NOTES:

1. SEDIMENT SHALL BE REMOVED WHEN ONE HALF OF THE BASIN DESIGN DEPTH HAS BEEN FILLED.
2. REMOVED SEDIMENT SHALL BE DEPOSITED IN AN AREA TRIBUTARY TO A SEDIMENT BASIN.

SEDIMENT TRAP



CITY OF
FORT COLLINS
UTILITIES
FORT COLLINS, CO.
(970) 221-6700

STORMWATER
CONSTRUCTION DETAILS

APPROVED:

DATE: 12/27/00

DRAWN BY: NBJ

DETAIL

D-22