



NOTE:

THE GAUGE SHALL BE CONSTRUCTED OF PRESSURE TREATED SQUARE POSTS MEASURING 6"x8" WITH BOTH 8" SIDES ROUTED WITH 6" NUMBERS AND GAUGING MARKS. THE ROUTED MARKINGS AND NUMBERS SHALL BE PAINTED WITH WHITE WATERPROOF PAINT. THE POST SHALL BE ONE FOOT TALLER THAN THE MAXIMUM DEPTH OF THE POND. THE POST SHALL BE EMBEDDED IN CONCRETE WITH A DIMENSION OF 16"x14"x3' IN DEPTH. THE GAUGE SHALL BE PLACED NEAR THE DEEPEST AREA OF THE POND, AND SHALL BE POSITIONED SO THAT IT CAN BE READ FROM THE NEAREST POINT OF PUBLIC ACCESS. THE PONDING DEPTH SHALL BE REFERENCED TO THE DEEPEST POINT OF THE POND.

DETENTION POND DEPTH GAUGE  
N.T.S.

DETENTION POND DEPTH GAUGE



CITY OF  
FORT COLLINS  
UTILITIES  
FORT COLLINS, CO.  
(970) 221-6700

STORMWATER  
CONSTRUCTION DETAILS

APPROVED:

DATE: 2/18/05

DRAWN BY: TDC

DETAIL

D-31