

BID PROPOSAL

BID 5946

FIBERGLASS TANKS

BID OPENING: November 30, 2005, 3:00p.m., (our clock)

WE HEREBY ENTER OUR BID FOR THE CITY OF FORT COLLINS' REQUIREMENTS FOR FIBERGLASS TANKS PER THE BID INVITATION AND ANY REFERENCED SPECIFICATIONS AND DRAWINGS:

The City of Fort Collins' is requesting bids for 2 - 21,000 gallon fiberglass tanks, per specification, to be delivered to the City of Fort Collins Streets Facility, 625 9th St, Ft Collins, Colorado. Tanks must be delivered by February 23, 2006 or as approved by City Representative.

Technical questions for the tanks should be referred to Stan Welsch at 970-416-2091. Purchasing questions should be referred to John Stephen, CPPO, CPPB, Senior Buyer at 970-221-6777.

BID SCHEDULE

Furnish and deliver 2(two) - 21,000 gallon fiberglass tanks to 625 9th street, Fort Collins, Colorado.

\$ 17,466.00 each x 2 = \$ 34,932.00 TOTAL

FIRM NAME J-8 EQUIPMENT COMPANY
Are you a Corporation, Partnership, DBA, I.L.C, or PC

BY: *Matthew J. Titus* Signature MATTHEW J. TITUS Printed

ADDRESS 1305 OSAGE STREET
DENVER, CO 80204

PHONE/FAX # 303-629-6881/303-571-5626

EMAIL: J8MT@IX.NETCOM.COM

Specification

1. 12' diameter x 25' high, 21,000 gallon, vertical, flat bottom, closed top, single wall fiberglass tanks designed for 1.6 S.G. and to store an undisclosed product.
2. Tanks must be built of ISO Resin/c-veil liner and ortho resin/fiberglass filament structure to ASTM-3299.
3. Tanks must include:
 - 2 - 4" flanges with gussets (1 siphon)
 - 1 - 4" vent with screen
 - 1 - ¾" sight gauge with stainless steel valve and wind guard
 - 1 - 24" manway
 - Lift lugs
 - Tie downs
4. Vendor must send shop drawings to City for approval.
5. Include freight to Fort Collins Colorado.