

Additional Comments:

AUG 29 1974 Final insp: Building occupied w/o approval - Corridors not protected as for one - hour construction: doors - hardware - fire dampers - ducts penetrating corridor walls - framing exposed under stairway - cables penetrating one hour ceilings and walls - access panels are not rated panels - illegal steps and hand rails.

Met with Carmichael - Cahill - DeLozier and Architects Rep. <sup>and City</sup> - decision was to provide guard until another meeting on 9-4-74 WALDO

SEP 9 1974 Met with architects - Contractor and Mountain Bell representatives in regard to completing building WALDO

DEC 9 1974 DEC 12 1974

O A Fire Inspector HOFFMAN

Call Howard DeLozier

Called John 2-3-75 re Hts + g.p permits