

File Safeway Store

106 E. Fort Collins Parkway

beckett
harmon
associates, inc.
engineers

November 9, 1974

Plans Checker
Building Department
City of Fort Collins
300 La Porte Avenue
Ft. Collins, Colorado 80521

Re: Safeway Store No. 907

Dear Sir:

The following will confirm our telephone conversation on November 7, 1974 concerning the oven-range hood for the Safeway Store. Galvanized steel of minimum sheet gauge 22 is acceptable.

If there are any exceptions to this, please contact me immediately.

Sincerely,

BECKETT-HARMON ASSOCIATES, INC.
Boulder, Colorado

Coleen Murray

Coleen B. Murray

sh

RECEIVED BY BUILDING INSPECTION
NOV 11 1974