



City of Fort Collins

MINOR AMENDMENT COMMENT SHEET

Current Planning

COPY

DATE: May 30, 2002 TO: **Engineering**

PROJECT: #16-90D City of Fort Collins Utility Service Center –
Amended ODP Minor Amendment

All comments must be received by **Ted Shepard** no later than the staff
review meeting:

June 19, 2002


Note - Please identify your redlines for future reference


No Comments

Name (please print)

CHECK HERE IF YOU WISH TO RECEIVE COPIES OF REVISIONS

Plat Site Drainage Report Other _____
 Utility Redline Utility Landscape





Project Comments Sheet Selected Departments

Department: **Engineering**

Date: **June 28, 2002**

Project:
CITY OF FORT COLLINS UTILITY SERVICE CENTER PDP/REPLAT

All comments must be received by TED SHEPARD in Current Planning no later than the staff review meeting:

June 26, 2002

Note - Please identify your redlines for future reference

Issue Contact: Dave Stringer

Topic: General

10

Need to add signature block for ELCO

11

Is signature block required for Griffin Drain ownership?

12

Add note to demo plan about remove and replace any damaged curb and gutter on Elm Street in area to be constructed

13

Call out curb and gutter type, Elm Street and parking lot

14

Show location of Griffin Drain on x-section sheet CS302

15

Will existing Fire hydrant on Elm need to be relocated? The valve may be in Gutter or curb head

16

Appears off-site easements are require for pond, retaining wall and trail

Signature

Date

CHECK HERE IF YOU WISH TO RECEIVE COPIES OF REVISIONS

Plat **Site** **Drainage Report** **Other** _____
 Utility **Redline Utility** **Landscape**

17

How will existing alley terminate at the North end?

18

Provide elevations of existing gutter at Loomis and Elm for tie in points



Project Comments Sheet Selected Departments

COPY

Department: **Engineering**

Date: **October 9, 2002**

Project:

**CITY OF FORT COLLINS UTILITY SERVICE CENTER PDP/REPLAT &
FINAL COMPLIANCE**

All comments must be received by TED SHEPARD in Current Planning no later than the staff review meeting:

October 09, 2002

Note - Please identify your redlines for future reference

Issue Contact: **Dave Stringer**

Topic: Plat

60

NW corner/NE1/4/NW1/4 is not described,

61

NW corner not discribed,

62

This product will be hard to scan due to text format refer to appendix E-6 in recently approved LUCASS for guidance

Topic: Utility plans

59

Engineering ready for Mylars, Still need approval from other departments.
Easements need to go to Council for approval

Signature

10/9/02
Date

CHECK HERE IF YOU WISH TO RECEIVE COPIES OF REVISIONS

Plat Site Drainage Report Other
 Utility Redline Utility Landscape