

TO: Frank Fisch, Street Department  
FROM: Mike McDill, Engineering Services  
RE: Subdivision Utility Plans

Date: 11-30-77

Submitted for your review and comment are utility plans for Collindale,  
First Filing

---

Please respond at your earliest convenience.

*No storm drain under 12"  
has to be concrete*

TO: Don Hisam, Fire Prevention Bureau

FROM: Mike McDill, Engineering Services

RE: Subdivision Utility Plans

Date: 11-30-77

Submitted for your review and comment are utility plans for \_\_\_\_\_

Collindale, First Filing

Please respond at your earliest convenience.

11-30-77

OK As Shown -

D. HISAM  
Fire Dept.

TO: Doug Martine, Light and Power Department

FROM: Mike McDill, Engineering Services

RE: Subdivision Utility Plans

Date: 11-30-77

Submitted for your review and comment are utility plans for \_\_\_\_\_

Collindale, First Filing

Please respond at your earliest convenience.

→ MIKE McDILL

STREETLIGHTS SHOWN ON SHEET #2  
NO OTHER COMMENTS

*Doug*

date: 12/19/77 department: Engineering

DEPARTMENT COMMENTS: SUBDIVISION/P.U.D. FINALS

ITEM:

Collindale 1<sup>st</sup>, FINAL

COMMENTS:

- 1.) Easements & right-of-ways should be dedicated to the City of Fort Collins, not "to public use".
- 2.) All curve with less than 250 R. are UNDER designed for 25 m.p.h.. Radius to be measured at the R.O.W. centerline.
- 3.) Utility Plans not approved.