

DATE: 6/6/89

DEPARTMENT: Eng.

ITEM:

# 26-89 Graham PUD - Bed & Breakfast

No Problems

Problems or Concerns (see below)

- Dedicate 20' of ROW + 15' of utility easement on Prospect Rd.
- Construct a 5' detached walk along Prospect
- Construct a driveway using concrete in the public ROW.
- Site plan okay to show improvements  
No utility plan needed.

Date 6/14/89

Signature *M. Benzig*