

M E M O R A N D U M

TO: P.S.  
GARY HUATT

FROM: Mike Herzig, Development Engineering Manager

DATE: 4/22/92


RE: UTILITY PLANS

Submitted for your review and comment are utility plans for:

WATER LINE EXTENSION - LOT 7 OBSERVATORY HEIGHTS

Please respond by: 4/28/92

WATER LINE EXTENSION - LOT 7 OBSERVATORY HEIGHTS  
WATER LINE EXTENSION - LOT 7 OBSERVATORY HEIGHTS  
WATER LINE EXTENSION - LOT 7 OBSERVATORY HEIGHTS



M E M O R A N D U M

TO: *US. WEST*  
*SUSAN PATTERSON*

FROM: Mike Herzig, Development Engineering Manager

DATE: ~~6/1~~ *4/22/92*

RE: UTILITY PLANS

Submitted for your review and comment are utility plans for:


*WATER LINE EXTENSION - LOT 7, OBSERVATORY HEIGHTS*

Please respond by: *4/28/92*

*4-22-92*

*Locate telephone cable crossing  
Mitchell Dr. North of Western auto  
building before digging.*

*S Herzig*



M E M O R A N D U M

TO: FIRE  
REC'D FRASCO

FROM: Mike Herzig, Development Engineering Manager

DATE: ~~FIRE~~ 4/22/92

RE: UTILITY PLANS

Submitted for your review and comment are utility plans for:

WATER LINE EXTENSION - LOT 7 OBSERVATORY HEIGHTS

Please respond by: 4/28/92


OK w/ Eger  
as shown  
on revised  
plan 5/11/92

Existing Hydrant is For Water Supply to  
Western Auto + potentially Toys-R-Us -

The Re Location Does not provide Fire Dept  
Access so will not meet our needs  
Unless Mitchell Drive is improved to City  
Standards.

We have no objection to installing the  
North Hydrant as long as the existing  
Hydrant is left as is.

R. Frasco



M E M O R A N D U M

TO: *Stammert*  
*and Stammert*

FROM: Mike Herzig, Development Engineering Manager

DATE:

RE: UTILITY PLANS

Submitted for your review and comment are utility plans for:

*Water line ext. - Lot 7 OBSERVATORY HEIGHTS*

Please respond by: *4/28/92*

*Do not see any immediate problem so should be OK. Engineer or owner should consider if any storm sewer lines will ever need to cross this section of Mitchell Drive. If so the line could potentially need to be lowered to accommodate a gravity outfall.*

*Glen Schuster*