

RECEIVED  
FIRE DEPT.  
FORT COLLINS

TO: Don Hisam, Fire Prevention Bureau  
FROM: Lloyd McLaughlin, Engineering Services 9-16-77  
RE: Subdivision Utility Plans

Submitted for your review and comment are utility plans for \_\_\_\_\_  
OVERLAND TRAIL FARM

Please respond at your earliest convenience.

*Note: Fire hydrants are not shown on the plans. Perhaps it would be best for us to indicate where hydrants are desirable and then return plans for their addition. I have suggested locations in red. LHM*

*Look over plans and let me know what you think. I have suggested hydrant locations in red. If you have any questions, please call me. LHM*

LM:cs

TO: Tom Hays, Water and Sewer Utility Department  
FROM: Lloyd McLaughlin, Engineering Services 9-16-77  
RE: Subdivision Utility Plans

Submitted for your review and comment are utility plans for \_\_\_\_\_  
OVERLAND TRAIL FARM

Please respond at your earliest convenience.

Valves required as shown.  
Should also show 42" water line on  
Overland Trail.

FIRE HYDRANT LOCATIONS AS SHOWN.

LM:cs