



City of Fort Collins

PROJECT COMMENT SHEET

Current Planning

DATE: July 9, 1998 TO: **Engineering**

PROJECT: #29-98 115 Hickory Street.- (LUC) Type II PDP Review

All comments must be received by Mike Ludwig no later than the staff review meeting:

Wednesday, August 12, 1998

115 Hickory Street

August 10, 1998

Eliminate the first parking stall (closest to the street) and move the others toward the building. Even with this you are not meeting the parking set back (50 feet for a collector). A variance to this standard needs to be submitted or another parking stall needs to be eliminated.

Provide a walk from the street to the building. If there is a curb along this walk than curb stops are not needed.

Provide detail D-11 Curb and Gutter Details and detail D-15 New Driveway Approach Detail for modifying the driveway width.

Provide Utility Plan signature block on the utility plans.

Add the general notes that are indicated on the site plan.

Date:

8/2/98

Signature:


S. Wankoff

CHECK HERE IF YOU WISH TO RECEIVE COPIES OF REVISIONS

Plat Site Drainage Report Other _____
 Utility Redline Utility Landscape



City of Fort Collins



City of Fort Collins

Current Planning

PROJECT COMMENT SHEET

DATE: July 9, 1998 TO: Engineering Pvmt.

PROJECT: #29-98 115 Hickory Street - (LUC) Type II PDP Review

All comments must be received by Mike Ludwig no later than the staff review meeting:

Wednesday, August 12, 1998

*If any work is needed on Hickory Street
a Soils Report will be needed.*

Date:

8-23-98

Signature:

[Handwritten Signature]

CHECK HERE IF YOU WISH TO RECEIVE COPIES OF REVISIONS

Plat Site Drainage Report Other _____
 Utility Redline Utility Landscape





City of Fort Collins

Current Planning

PROJECT COMMENT SHEET

DATE: July 9, 1998 TO: Engineering

PROJECT: #29-98 115 Hickory Street.- (LUC) Type II PDP Review

All comments must be received by Mike Ludwig no later than the staff review meeting:

Wednesday, August 12, 1998

115 Hickory Street

August 10, 1998

Eliminate the first parking stall (closest to the street) and move the others toward the building. Even with this you are not meeting the parking set back (50 feet for a collector). A variance to this standard needs to be submitted or another parking stall needs to be eliminated.

Provide a walk from the street to the building. If there is a curb along this walk than curb stops are not needed.

Provide detail D-11 Curb and Gutter Details and detail D-15 New Driveway Approach Detail for modifying the driveway width.

Provide Utility Plan signature block on the utility plans.

Add the general notes that are indicated on the site plan.

Date: 8/12/98 Signature: S. Wankoff

CHECK HERE IF YOU WISH TO RECEIVE COPIES OF REVISIONS

- Plat
- Site
- Drainage Report
- Other _____
- Utility
- Redline Utility
- Landscape



City of Fort Collins