



City of Fort Collins

Current Planning

PROJECT COMMENT SHEET

DATE: September 16, 1997 DEPT: **Engineering**

PROJECT: #3-94J (Replat of Tract C & D) Willow Springs
P.U.D., 5th Filing - Type 1 (LUC) PDP/FC

PLANNER: Ted Shepard

All comments must be received no later than the staff review meeting:
Wednesday, October 15, 1997


* An access easement needs to be provided across Tract C to
Tract D.

Date: 10/14/97 Signature: S. Wanhoff

CHECK HERE IF YOU WISH TO RECEIVE COPIES OF REVISIONS

Plat Site Drainage Report Other _____
 Utility Redline Utility Plat Landscape





City of Fort Collins

Current Planning

PROJECT COMMENT SHEET

DATE: 2/27/98

DEPT: Engineering

PROJECT: Willow Springs PUD - 5th filing

PLANNER:

ENGINEER: Sheri Wankhoff



No Problems

Problems or Concerns (see below or attached)

Since these are not revisions to a previous project, but it's own project (5th filing) with its own plat. This needs to be a complete set of utility plans. i.e. a coversheet w/ general notes ^{& index of sheets} is needed. The plat is the second ~~set~~ page of the set. detail sheets w/ all details needed for this project provided.


* Need ramp details - ~~at~~ for entrance drive, & mud block etc.

Date: 2/27/98

Signature: S. Wankhoff

PLEASE SEND COPIES OF MARKED REVISIONS:

- PLAT
- SITE
- UTILITY
- LANDSCAPE



REVISION COMMENT SHEET

DATE: November 11, 1997 TO: **Engineering**

PROJECT: #3-94J Willow Springs P.U.D., 5th Filing,
Tract C & D - Type I (LUC) PDP

All comments must be recieved Ted Shepard no later than the staff
review meeting:

Wednesday, December 3, 1997

No Comments

Date:

12/5/97

Signature:

Shirley L. Wenzel

CHECK HERE IF YOU WISH TO RECEIVE COPIES OF REVISIONS

Plat Site Drainage Report Other _____
 Utility Redline Utility Landscape





City of Fort Collins

Current Planning

PROJECT COMMENT SHEET

DATE: 4/1/97

DEPT: Engineering

PROJECT: WILLOW SPRINGS PLD, 534th filing

PLANNER: COUNTRY STORE

ENGINEER: Sheri Wanhoff

Please return to Sheri by 4/23

- No Problems
 Problems or Concerns (see below or attached)

FIRE Hydrants AS SHOWN ON SITE PLAN ARE OK

HMA @ time of FINAL

Date: 4-2-97

Signature: Roger Franco

PLEASE SEND COPIES OF MARKED REVISIONS:

- PLAT
- SITE
- UTILITY
- LANDSCAPE



City of Fort Collins

PROJECT COMMENT SHEET

Current Planning

DATE: January 21, 1997 DEPT: Engineering

PROJECT: #3-94H Willow Springs PUD, 5th Filing
Country Store - Preliminary

PLANNER: Ted Shepard

All comments must be received by: Monday, February 10, 1997

Willow Springs PUD, 5th Filing, Country Store - Preliminary
Site/ Landscape

February 13, 1997

1. The entrance radii need to be a 15 foot radius. **DONE**

Utility Plans

2. The entrance radii need to be a 15 foot radius. **DONE**

Date: 2/13/97 Signature: S. Warkoff

CHECK IF YOU WISH TO RECEIVE
COPIES OF REVISIONS

- PLAT
- SITE
- LANDSCAPE
- UTILITY



City of Fort Collins

PROJECT COMMENT SHEET

Current Planning

DATE: January 21, 1997 DEPT: **Engineering**

PROJECT: #3-94H Willow Springs PUD, 5th Filing
Country Store - Preliminary

PLANNER: Ted Shepard

All comments must be received by: Monday, February 10, 1997

Willow Springs PUD, 5th Filing, Country Store - Preliminary
Site/ Landscape

February 13, 1997

1. The entrance radii need to be a 15 foot radius.

Utility Plans

2. The entrance radii need to be a 15 foot radius.

Date: 2/13/97 Signature S. Warkoff

CHECK IF YOU WISH TO RECEIVE
COPIES OF REVISIONS

- PLAT
- SITE
- LANDSCAPE
- UTILITY