



PROJECT COMMENT SHEET

DATE: 1 June 92 DEPARTMENT: *ENGINEERING*

ITEM: 50-83B Windmere Professional Park Minor
Subdivision

Please review this Minor Subdivision prior to the monthly submit-
tal items and respond by Monday, June 8, 1992. Thank you.

Planner: Kirsten Whetstone

No Problems

Problems or Concerns (see below)

- Should the driveway connection to Riverside be required at a specific time or traffic service level in the future? Traffic
- Driveway design onto Riverside Prospect must be completed. ~~See~~ See comments in utility plans
- Riverside planned for an overlay this summer utility cuts should be installed first.

Date: *6/7/92*

Signature: *M. Herzig*

CHECK IF REVISIONS REQUIRED:

<input checked="" type="checkbox"/>	PLAT
<input checked="" type="checkbox"/>	SITE
<input checked="" type="checkbox"/>	LANDSCAPE
<input checked="" type="checkbox"/>	UTILITY