



COPY

PROJECT COMMENT SHEET

Current Planning

DATE: September 16, 2000 **DEPT: ENGINEERING**

PROJECT: #30-00, 3000 South College – Wireless

Telecommunications Facilities- Type I (LUC)

All comments to be received by **Troy Jones** no later than the staff review meeting: **September 27, 2000**

- ◆ Set back of pole may not meet Code. 3.8.13 (c) (1) requires 1 foot of set back for 1 foot of height from property line.
- ◆ Show State right-of-way on plan view
- ◆ Proposed easement appears to be inside ditch company easement – need their approval
- ◆ Show x-section of pole base location with ditch bank
- ◆ Include picture exhibit of easement with point of beginning, distances and bearings
- ◆ Identify what dashed lines are
- ◆ Show access easement and how it will work for emergency vehicles, may need to be dedicated as emergency access easement

Date: *9-22-00*

Signature: *Troy Jones*

PLEASE SEND COPIES OF MARKED REVISIONS: PLAT SITE

UTILITY
 LANDSCAPE