



City of Fort Collins

Current Planning

# PROJECT COMMENT SHEET

DATE: April 2, 1998 TO: Engineering

PROJECT: #19-98 Poudre R-1 Putnam Elementary - (LUC)  
Site Plan Advisory Review

All comments must be received by Ted Shepard no later than the staff review meeting:

**Wednesday, April 29, 1998**

1. need to provide utility plans for C&G and sidewalk being proposed on Cherry street. Show how drainage flows - to slope, C&G type, sidewalk grade.
2. limits of curb and repairs with elevations of gutter lip to existing asphalt edge

Date:

4-29-98

Signature:

David [Signature]

CHECK HERE IF YOU WISH TO RECEIVE COPIES OF REVISIONS

Plat       Site       Drainage Report       Other \_\_\_\_\_  
 Utility       Redline Utility       Landscape

