



REPORT OF NEW PAVEMENT INSTALLATION

New Street
 Overlay Existing Street

Widen Existing Street
Previous Width _____
New Width _____

Upgrade Existing Street
Previous Surface Type _____
New Surface Type _____

Street Name Bullrush Court, Sawgrass Court

Subdivision/Project Mirror Mont 2nd

Contractor Schwartz/Western Mobile

Completion Date 6-94

Traffic Designation: Local
 Collector
 Arterial

Pavement Section:

Asphalt (Concrete) 3"
Base 4"
Sub-base 12" Fly Ash

Dimensions:

Street Width: 28 Feet
Street Length: 1075 Feet
.20 Miles
Square Yards of New Surface: _____
Square Yards of New Street: 3344

Surface Classification Guidelines	
Type A.	Primitive Road: Unimproved but useable by conventional vehicles.
Type B.	Bladed Road: Bladed but not drained.
Type C.	Graded & Drained: Aligned, graded, crowned and drained by ditches.
Type E.	Gravel: Same as "C" but gravel surface.
Type F.	Bituminous Surface-Treated Road (Low Type): Same as "E" with an added bituminous surface course of less than one inch thickness.
Type G.	Mixed Bituminous Road (High Type): Gravel base with bituminous surface course of more than one inch thickness.
Type J.	Portland Cement Concrete Road: Concrete road with or without bituminous wearing surface of less than one inch thickness.
Type K.	Brick Road

Construction Limits:

Beginning Point: Highcastle Drive
Ending Point: End of Calderac's

Comments/Sketches:

Inspected by: TODD Checked by: _____

Copy to Transportation Division
Original to Annual Street Report



City of Fort Collins
Engineering Department

REPORT OF NEW PAVEMENT INSTALLATION

New Street
 Overlay Existing Street

Widen Existing Street
Previous Width _____
New Width _____

Upgrade Existing Street
Previous Surface Type _____
New Surface Type _____

Street Name Highcastle Drive

Subdivision/Project Mirror ment 2nd

Contractor Schmidt/Western Mobile

Completion Date _____

Traffic Designation: Local
 Collector
 Arterial

Pavement Section:

Asphalt (Concrete) 3"
Base 6"
Sub-base 12" Fly Ash

Dimensions:

Street Width: 36 Feet
Street Length: 600 Feet
.11 Miles
Square Yards of New Surface: _____
Square Yards of New Street: 2400

Surface Classification Guidelines	
Type A.	Primitive Road: Unimproved but useable by conventional vehicles.
Type B.	Bladed Road: Bladed but not drained.
Type C.	Graded & Drained: Aligned, graded, crowned and drained by ditches.
Type E.	Gravel: Same as "C" but gravel surface.
Type F.	Bituminous Surface-Treated Road (Low Type): Same as "E" with an added bituminous surface course of less than one inch thickness.
Type G.	Mixed Bituminous Road (High Type): Gravel base with bituminous surface course of more than one inch thickness.
Type J.	Portland Cement Concrete Road: Concrete road with or without bituminous wearing surface of less than one inch thickness.
Type K.	Brick Road

Construction Limits:

Beginning Point: Boardwalk Drive
Ending Point: End of Highcastle Drive (600' South of Boardwalk)

Comments/Sketches:

Inspected by: TODD Checked by: _____

Copy to Transportation Division
Original to Annual Street Report



REPORT OF NEW CONCRETE INSTALLATION

Subdivision or Project Mirror Mountain 2nd

Contractor C.G.E.S

Date Work Started 10-1-93

Date Work Completed 4-1-94 Inspector TODD

Drive-over curb, gutter & walk

Sidewalk: width 3'9"

Vertical curb & gutter

Radius: number 6

Drive-over curb & gutter

Cross-pan: number 2

Other (specify) _____

Catch basin: number 1

Limits or Location of Work: From Boardwalk Drive to End of High Castle Drive
(Bullrush Ct, Sangre de Cristo Court, High Castle Dr.)

Total Linear Footage Installed (report for curb, gutter and/or sidewalk) 3325 L.F.

COMMENTS:

Checked by: _____