

DIVISION 2

SECTION 02306 – RECONDITION SUBGRADE

PART 1 – GENERAL

1.01 Scope

- A. This work shall consist of blading, shaping, wetting, and compacting the subgrade with moisture density control, in accordance with these specifications, at locations and in reasonably close conformity with the details shown on the plans or as staked.

PART 2 – MATERIALS – Not used

PART 3 – EXECUTION

3.01 Construction Requirements

- A. The top 6 inches of the entire subgrade, UNLESS OTHERWISE SHOWN ON THE DRAWINGS shall be reconditioned by scarifying, blading, and rolling. Sufficient water shall be added to meet the density requirements as specified on the plans. The reconditioned surface shall not vary above or below the lines and grades as staked by more than 0.08 foot. The surface shall be tested prior to the application of any base course material. Where bituminous surfacing materials are to be placed directly on the subgrade, the subgrade plane shall not vary more than .04 foot. All defective work shall be corrected as directed. The surface shall be satisfactorily maintained until base course has been placed.
- B. Compaction shall be 95% of ASTM D698 UNLESS OTHERWISE SHOWN ON DRAWINGS.

END OF SECTION